

Kentucky - Office of Inspector General  
**Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes**  
**During FY 2017 (10/01/2016 - 09/30/2017)**

**FED - K307 & K308 - K-LSC 2012 Health Existing & Health New**

Tag	# of Citations
<b>0353</b> - Sprinkler System - Maintenance and Testing	4
<b>0211</b> - Means of Egress - General	3
<b>0351</b> - Sprinkler System - Installation	3
<b>0511</b> - Utilities - Gas Electric	3
<b>0321</b> - Hazardous Areas - Enclosure	2
<b>0291</b> - Emergency Lighting	1
<b>0324</b> - Cooking Facilities	1
<b>0345</b> - Fire Alarm System - Testing and Maintenance	1
<b>0361</b> - Corridors - Areas Open to Corridor	1
<b>0363</b> - Corridor - Doors	1